

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 2135

Dated: 29/5/2026

It is certified that an inspection team headed by AVINASH SINGH PARMARTH ..
 (Name of Officers with designation) from EXECUTIVE ENGINEER ..
 (Name of Department/ Office) inspected the CREANE MEMORIAL HIGH SCHOOL, Katari Hill
Road, Gaya, Bihar – 823 001..... (Name & Address of the school) on 19/5/2026.....(date
 of inspection) and found that the CREANE MEMORIAL HIGH SCHOOL (Name of school) has
 safe drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per norms prescribed by the
 Central/ State/ U.T. Govt. The above is valid for a period of ONE YEAR ..

Signature with Seal: 29/5/2026 ..
 Name : AVINASH SINGH PARMARTH ..
 Designation : EXECUTIVE ENGINEER ..
 Name & Address of the Office / Department : P.H. DIVISION
GAYA ..

To

CREANE MEMORIAL HIGH SCHOOLKatari Hill Road, Gaya, Bihar - 823001

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language,
 translated notarized version in English be uploaded along with the original vernacular certificate as a
 single pdf.

P. Banerjee
16/06/2026
 Principal
 Creane Memorial High School
 Katari Hill Road
 Gaya (Bihar)

P. Banerjee
 Secretary
 Creane Memorial High School
 Gaya (Bihar) 823001

Govt. Of Bihar
DISTRICT LEVEL WATER QUALITY TESTING LABORATORY (DLWQTL)
Public Health Engineering Department
P.H. DIVISION, GAYA

Physico-Chemical and Bacteriological Examination Report of Drinking Water Samples of Gaya

CREANE Memorial High School														Sample Received on : 19/05/26									
Sample Collected By:		Amit Bhusnan singh	Katari Hill Road Gaya																				
Sample no	Block Name	Panchayat Name	Village	Wardno	Turb.	Conductivity	TDS	Hardness	Calcium	Magnesium	Chloride	Alkalinity	Fluoride	PH	Nitrate	Iron	Sulphate	Bacteria (+,-)	Remarks				
1	Chanduat	Chanduat	Chanduat	29	0.37	170	110	92	25.65	6.8	27.99	108	0.39	7.15	-	-	10	Absent					
Reporting Date :	25.05.26	Desirable Limit			1.00 NTU	-	500 (mg/l)	200 (mg/l)	75 (mg/l)	30 (mg/l)	250 (mg/l)	200 (mg/l)	1.00 (mg/l)	6.5-8.5	45 (mg/l)	1.00 (mg/l)	200 (mg/l)	Absent					
missible Limit in absence of alternate source IS:10500:2012					5.00 NTU	-	2000 (mg/l)	600 (mg/l)	200 (mg/l)	100 (mg/l)	1000 (mg/l)	600 (mg/l)	1.50 (mg/l)	NR	NR	NR	400 (mg/l)	Absent					

*NR-No Relaxation,,BDL-Below Detection Limit

जल नमूना का संग्रह दिनांक 19.05.26
Amul-Bottle द्वारा किया गया है।

P.H.Division, Gaya

Chemist

19/05/2026

T. Pule

Principal
Creane Memorial High School,
Katari Hill Road
Gaya (Bihar)

Secretary
Creane Memorial High School,
Gaya (Bihar) 823001